

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: March 2024

Report:

Collections

- Televised-3058 ft. of Sanitary
- Sewer calls-4
- Main line cleaned- 15000ft.
- 1lift station cleaned
- The collections crew also spent over 20hrs repairing televising equipment and doing other fleet maintenance.

Operations/Maintenance

- All effluent discharge limits were well within permit limits.
- Worked on pouring a concrete pad for the new pump at 1st and 2 mile
- Finished rebuilding a spare RAS pump.
- Replaced Roots blower on generator conditioning skid
- Troubleshooting and seal replacement on W3 water system
- Waxed floors
- Ras pump #2 VFD replaced
- Fixed UV disinfection communication issues
- Controls for Westside pumping station were re-configured.

Plant administration.

- Put together a sludge management plan for the DNR for steps to distribute and control our sludge.
- Continued to do lab testing for volatile organics to help optimize the plant biology.
- Continued to do extra lab testing to identify where high molybdenum levels are coming from.
- Continued working with contractors to develop a plan to replace Dewey MCC lift station.
- Staff spent time reviewing and modifying the right-of-way lateral repair policy.