

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: July 2023

Report:

Collections

- Televised-3200 ft
- Sewer calls-4
- Main line cleaned- 1500ft
- Root cutting- 400ft
- The collections crew also spent time cleaning lift stations, working for water and light, and helping bypass Whitrock lift station for manhole rehab work. The crew also assisted the streets department with catch basin repairs.

Operations/Maintenance

- Overall, plant treatment was sufficient, and all parameters were well under the permitted limits.
- Device Network issues caused communication issues with plant equipment. Operators were able to work around it until a technician could replace the hardware.
- Maintenance pulled a RAS pump for repair, worked on the generator and troubleshot alarms, replaced a door in building 150, and serviced several pieces of equipment.

Plant administration

- Sampled extra PCB testing to try and remove it from the future permit.
- Worked on getting information to Donohue for the Westside interceptor project.
- Coordinated manhole inspections and a manhole rehab project.
- Went through next year's Capital improvement projects list with engineering
- Worked on budget items for the 2024 budget.