

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: August 2023

Report:

Collections

- Televised-4360 ft
- Sewer calls-4
- Main line cleaned- 3265ft
- Lift stations cleaned-11
- The collections crew also spent time assisting in bypassing the Whitrock lift station so manhole rehab could take place. They also assisted HK solutions with manhole repairs and performed maintenance on the televising equipment.

Operations/Maintenance

- Overall, plant treatment was excellent, and all parameters were well under the permitted limits. Industry had a very good month with low monthly loadings.
- The biogas engine was shut down for a few days due to a pinhole leak on the gas conditioning chiller. Ron's refrigeration was called to fix this.
- Multiple doors were rotted out at the treatment plant and are being replaced by the maintenance crew.
- Pepper Lift station check valves were leaking and were rebuilt.
- North final clarifier is down due to the plant running optimal. This is allowing for the staff to replace the center manifold gasket.
- Staff replaced a 3 way plug that was leaking in between the digesters.

Plant administration

- Submitted televising reports of manholes to Donohue for the Westside interceptor project.
- Pre-construction kickoff meeting to rehabilitate 17th avenue south from the Round-a-bout to Russell St.
- Submitted fertilizer application license and tonnage fees.
- Continued to put 2024 budget together.
- Worked with the streets department to coordinate "right of way" lateral repairs for 3 different houses.