

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: February 2024

Report:

Collections

- Televised-5000 ft. of Sanitary
- Sewer calls-2
- Main line cleaned- 45,000ft.
- 2 lift stations cleaned
- Helped bypass 1st and 2mile lift station for valve replacement.

Operations/Maintenance

- All effluent discharge limits were well within permit limits.
- finished removing old pump at 1st and Two mile lift station to prepare for valve and pump replacement.
- Performed a bypass on 1st and 2mile lift station to replace 2 plug valves.
- Performed polymer trials with a new vendor.
- Maintained the UV light to get ready for disinfection season.
- Performed troubleshooting on the UV system for communication failures.
- Cleaned the carpets in the administration building.
- Continued to Clean and organize buildings.

Plant administration.

- Met with Rudolph to discuss manhole replacement.
- Coordinated backflow preventer inspections and repairs.
- Did lab testing for volatile organics to help optimize the plant biology.
- Continued to do extra lab testing to identify where high molybdenum levels are coming from.
- Coordinated a bypass with septage haulers and put a plan in place to bypass 1st and 2mile lift station.
- Continued working with contractors to develop a plan to replace Dewey MCC lift station.
- Staff spent time reviewing and modifying the right-of-way lateral repair policy.