

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
DATE: March 2022

Report:

Collections

- In March, collections system staff did not televise due to our camera being in the shop for an upgrade.
- Collections flush 126 dead ends, and root cut 3200ft , to insure proper conveyance of the sanitary system. They also responded to 3 sewer calls.
- Staff spent time flushing lines used primarily for commercial customers.
- Both 2 mile lift station and Westside lift station were cleaned with the help of plant staff.
- Collections spent time going over capital improvement projects with the superintendent.

Operations/Maintenance

- All effluent parameters were in complete permit compliance in March.
- Heavy industrial loading is causing high influent BOD loadings and settling issues at the plant, but the overall effluent looks good.
- With the help of the city garage, plant staff was able to distribute approximately 900 tons of biosolids before road limits went into effect.
- Maintenance spent time working on air handlers, Generator maintenance, Air dryer issues, and Miscellaneous maintenance issues.
- Exceptional Quality Class A biosolids are available for residents and companies to come and take for their use as state certified commercial fertilizer. The drying pad is filling up over the winter and is ready to be distributed.