

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: April 2023

Report:

Collections

- Televised-3080 ft
 - Laterals inspected-2
 - Sewer calls-4
 - Root cutting- 320ft
 - Mainline flushed- 21,086ft
-
- The collections crew also assisted the streets department cleaning catch basins, assisted the parks department clean out tanks at the aquatic center, and cleaned 3 lift station wet wells. They also cleaned and hauled out the grit pad full of catch basin material and helped removed foam out of aeration basin.

Operations/Maintenance

- Overall, plant treatment was sufficient, and all parameters were well under the permitted limits. Several rainy days, along with the river being high, caused high influent flows. The plant is continuing to take a lot of high strength waste in and produce a high percentage of its own electricity.
- Maintenance spent time rebuilding a spare RAS pump, replacing timers, motor savers, and power supplies in different equipment around the plant.
- Disinfection season started May 1st. Staff spent time cleaning, replacing, and installing UV lights.
- The new permit draft is now available, admin spent time reviewing the draft and figuring out all of the new parameters that need to be tested.