

TO: Mayor Matt Zacher
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: April 2024

Report:

Collections

- Televised-2100 ft. of Sanitary
- Sewer calls-2
- Main line cleaned- 3800ft.
- 10 lift station cleaned
- The collections crew also spent over 36hrs doing vac truck maintenance
- The crew also did plant and drying bed maintenance.

Operations/Maintenance

- All effluent discharge limits were well within permit limits.
- Ran conduit for new pump at first and 2 mile.
- Cleaned buildings and painted safety railings.
- Worked through PLC issues. Replaced EN2DN switch.
- Installed UV lights and ran practice E. Coli tests.
- Assisted cleaning lift stations.
- Hosted a plant tour for the WWOA North Central Regional meeting.

Plant administration.

- Finished sludge management plan. Started mixing sludge with compost to satisfy distribution requirements.
- Started bio-augmentation trial to help zoogical slime growth in the MBBR.
- Continued to do lab testing for volatile organics to help optimize the plant biology.
- Continued working with contractors to develop a plan to replace Dewey MCC lift station.
- Worked with Donohue to develop a scope for the influent channel project.
- Worked on letter to Strand for Westside lift station shortfalls.