

TO: Mayor Shane Blaser  
FROM: Derek Budsberg  
SUBJECT: Monthly Supervisory Report  
DATE: May 2022

Report:

#### Collections

- The collections crew televised 5,260 ft of sanitary and storm sewers.
- The crew flushed 3,905 ft of sewer and cleaned out 36 catch basins for the streets department.
- Collections responded to 2 sewer calls this month.
- The crew also finished up lateral launch training with Enviro-site and is beginning to use the new camera for pre and post construction projects.

#### Operations/Maintenance

- All effluent parameters were in complete permit compliance in May. Phosphorus fluctuated this month due to taking a higher amount of hauled waste, and lower BOD loading from industry. We were unable to meet the 0.36mg/l proposed new limit. Improved metering and lab testing adjustments can be made to monitor this better.
- Maintenance staff spent time replacing the pumps at the Pepper lift Station and the side stream lift station.
- Maintenance spent a large amount of time troubleshooting biogas chiller and generator issues. Clark energy has been involved assisting in trying to solve engine vibration issues.
- Staff assisted cleaning the septage receiving station to prevent the plugging of the septage receiving pump. This is done approximately 3 times per year to insure adequate operation of this equipment.
- Wastewater staff was able to coordinate a small haul and distributed 600 tons to local farmers. There is still plenty of biosolids from winter that need to be distributed.