

TO: Mayor Matt Zacher
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: July2024

Report:

Collections

- Televised-1940 ft. of Sanitary
- Main line cleaned- 440ft.
- Catch Basins cleaned-290
- Sewer calls-3 Lateral launched 2
- 16 hrs of sludge hauling
- 32 hours of plant maintenance

Operations/Maintenance

- New SCADA computers were installed.
- Took final clarifier down for cleaning and inspection
- Cleaned septage receiving tank
- Cleaned PAC tank
- Cleaned and maintained UV light system
- Re-plumbed water line for gas cannons
- Finished pump installation at 1st and 2mile lift station
- Digester foaming issues continued to be problematic
- Spent time on drying pad with loader trying to dry out biosolids
- Hauled 660 tons of biosolids
- Hauled grit to landfill

Plant administration.

- Coordinated annual flow meter calibration
- Discussed influent piping project with contractors
- Discussed Dewey MCC upgrade project
- Coordinated with farmers to find spots to distribute biosolids
- Continued extra Molybdenum sampling in sludge
- Worked on 2nd quarter industrial billing
- Landfill discharges caused disinfection issues