

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
DATE: August 2022

Report:

Collections

- The collections crew televised 8450 ft of sanitary sewer and 400 ft of storm sewer and have been continuing to inspect the westside of the city for potential Inflow and Infiltration points.
- The crew cleaned 2500 ft of mainline sewer and 200 ft of storm sewer and flushed 2 dead ends.
- Collections did not have to respond to any sewer calls.
- The crew assisted WWTP staff with cleaning 2 lift station wet wells.
- The crew set up a bypass on a 60inch storm line to clean and televise the line running underneath the West Jackson St. construction project.

Operations/Maintenance

- All effluent parameters were in complete permit compliance in August.
- The wastewater operator position has been filled. The new employee will start September 6th.
- Clark energy finished rebuilding the biogas engine and it is in full operation again.
- The plant capacitors were replaced to correct the power factor at the facility. The plant was paying penalties to WWLC because of the extra stress put on the incoming power lines. This has been corrected and it is now working properly.
- Maintenance spent time checking pumps, air reliefs, and check valves at the westside lift station. Staff performed several draw down tests to ensure the station is within design specifications.
- The Wisconsin fertilizer license for the plant's class "A" sludge was due for renewal.
- Biosolids are available under the covering at the westside compost site.