

TO: Mayor Matt Zacher  
FROM: Derek Budsberg  
SUBJECT: Monthly Supervisory Report  
Month of: August 2024

Report:

### **Collections**

- Televised-2308 ft. of Sanitary
- Main line cleaned- 3008ft.
- Catch Basins cleaned-94
- Sewer calls-2 Lateral launched 4
- 16 hrs of sludge hauling
- 8 hours of maintenance
- Hauled grit to landfill

### **Operations/Maintenance**

- All effluent parameters were within operating limits
- Took 2<sup>nd</sup> final clarifier down for cleaning and inspection. Put South clarifier back online.
- Generator valve checks
- Dewey Screener troubleshooting
- Replaced 3 way digester feed valve
- Cleaned aeration tanks
- Hauled sludge- hauled 1740 tons of biosolids to clean the drying pad.
- Digesters are continuing to improve and the plant is starting to take in normal High strength waste again.

### **Plant administration.**

- Biron mediation in Madison.
- Mercury PMP phone calls to local businesses.
- Met contractors at Dewey lift station to discuss options for MCC replacement.
- Re-applied for fertilizer license for biosolids and submitted payment for tonnage fees.
- Helped coordinate two Right of way lateral repairs.