

TO: Mayor Matt Zacher
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: September 2024

Report:

Collections

- Televised 6308 ft. of Sanitary-2398 ft. of storm
- Main line cleaned- 3670ft
- Catch Basins cleaned-9
- Sewer calls-2
- 16 hrs of sludge hauling
- Cleaned West Side liftstation
- Hydro excavating for catch basin rebuilds

Operations/Maintenance

- All effluent parameters were within operating limits
- Repaired scum beach on final clarifier and put it back online
- Repaired seal on primary clarifier drive shaft
- Pulled pump at Westside that will need to be rebuilt
- HSW flow meter troubleshooting
- Gas cannon water flow troubleshooting
- Changed out seized valves and piping in the basement in building 150
- Unplugged septage receiving station

Plant administration

- Wrote a letter to Metalco about high molybdenum levels in discharge water
- Submitted PCB progress report
- Worked on influent bypass pumping replacement
- Worked on Dewey liftstation MCC upgrade plans
- Went through budget items with the Mayor