

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: October 2023

Report:

Collections

- Televised-5010 ft.
- Sewer calls-4
- Main line cleaned- 3920ft
- Lift stations cleaned-2
- The collections crew had to spend many hours servicing the TV equipment. They assisted plant staff in cleaning the septage receiving station along with cleaning up the drying bed.

Operations/Maintenance

- Overall, plant treatment was excellent, and all parameters were well under the permitted limits.
- At the end of the month another final clarifier was put on line to help with the high flows from the heavy rains.
- Staff worked with a sludge hauler to clean the septage receiving station.
- UV disinfection season ended. October 1st. Staff removed the lights and cleaned and prepped them for use next year.
- Staff continued replacing exterior lights with new, energy efficient lights
- The new pumps were installed at the Westside lift station.

Plant administration.

- Administration attended the yearly WWOA conference.
- Continued work with Donohue for the Westside interceptor project.
- Samples were sent out for Mercury testing to comply with the mercury variance