

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
DATE: November 2022

Report:

Collections

- The collections crew televised 5050 ft of sanitary sewer and 6905 ft of storm sewer and have been continuing to inspect the westside of the city for potential Inflow and Infiltration points.
- The crew cleaned 1300 ft of mainline sewer and 1000 ft of storm sewer, root cut 1200ft of sanitary and storm, and flushed 2 dead ends.
- Collections had 4 sewer calls that were homeowner issues.
- The collections crew has been working on 2024 capital improvement projects, televising for preliminary engineering on Lincoln st..

Operations/Maintenance

- All effluent discharge concentrations were well under the permitted limits for November
- Energy dissipating baffles and a new skimmer arm have been installed on the North final clarifier and it is back up and running. The operations at the treatment plant had to be significantly altered to do this work, but everything has returned to normal operations.
- The plant continues to get slug loaded from landfill leachate. This has caused treatment issues with clarity and pin flocking.
- Haza mechanical replaced rusted out lines on the thermophilic digester heating lines. This involved keeping the heat loop off for the day and making sure all the work got done as fast as possible. The project went very well.