

TO: Mayor Shane Blaser
FROM: Derek Budsberg
SUBJECT: Monthly Supervisory Report
Month of: November 2023

Report:

Collections

- Televised-6004 ft. of Sanitary
- Sewer calls-6
- Main line cleaned- 3680ft
- The collections crew had to spend many hours cleaning manholes for rehab. They also assisted contractors lining 17th avenue S.

Operations/Maintenance

- Overall, plant treatment was excellent, and all parameters were well under the permitted limits.
- Hauled in waste is slowing down due to winter, causing some nutrient deficiency at the plant.
- Staff worked with a sludge hauler to clean the septage receiving station once more before winter.
- Staff continued replacing exterior lights with new, energy efficient lights.
- Staff fixed blowers, compressors, and pulled several lift station pumps due to rag build up.

Plant administration.

- The new Mercury ordinance limit was approved by council.
- The budget was approved by council.
- Met with Donohue to finish up the Facility report for the westside interceptor.
- The new permit comes into effect December 1st. Staff spent time reviewing and making changes to operations as needed.
- Staff spent time reviewing and modifying the right-of-way lateral repair policy.